

CAPACITY FEE SCHEDULE

INSTALLATION AND FEE COST TO BE BORNE BY PROPERTY OWNER

All costs and expenses specific to the installation and connection of the building sewer shall be borne by the owner. The owner shall indemnify to the Taney County Regional Sewer District, hereinafter referred to as the "District", from any loss or damage that may directly or indirectly be occasioned by the installation of the building sewer.

CAPACITY FEES

- A. All new commercial construction applying for a sewer connection permit shall pay a one time capacity fee for the use of the District's collection system at a cost of seven dollars and forty cents (\$7.40) per gallon per day of estimated wastewater flow.
- B. The capacity fee for all residential units, such as single-family residences, each half of duplex residences, apartment units, condo units, boarding houses, and mobile homes shall be one thousand five hundred dollars (\$1,500.00). Condo units with lockout rooms will have an additional two hundred fifty dollar (\$250.00) charge.

For all connections requiring a grinder pump to transport sewage from the structure to the sewer main, the owner shall assume the responsibility of operation and maintenance of the grinder pump themselves. Any unit that is connected to the District's low-pressure system must be of a type and design as approved by the District's Board of Trustees.

- C. The District, in accordance with the following criteria, shall determine the connection fee for all other types of buildings, and/or new construction: (The following uses, after all flows are calculated in gallons per day, shall be multiplied by the current rate which will equal the connection charge; exclusive of industrial waste.)

Type of Establishment	Flow
(Gallons per day (gpd) unless otherwise indicated)	
Commercial Facilities:	
Transportation Terminals (airports, bus stops, railroad, etc)	5 gpd/passenger
Laundromats	480 gpd/machine
Beauty Shops (Style Shops)	125 gpd/chair
Bowling Lanes	50 gpd/lane

Type of Establishment	Flow
(Gallons per day (gpd) unless otherwise indicated)	
Commercial Facilities: (continued)	
Business (other than those listed elsewhere in this table)	25 gpd/employee

Factories	25 gpd/person per shift
add for Showers	10 gpd/person per shift
Marinas	10 gpd/boat slip
with bathhouse	30 gpd/boat slip
Motel/Hotel/Resort	120 gpd/room
with cooking facilities	175 gpd/room
Offices (per shift)	25 gpd/person
Service Stations	250 gpd/restroom
24 Hour Service Stations	325 gpd/restroom
Movie Theaters	5 gpd/seat
Drive-In Theaters	15 gpd/space
Warehouses	30 gpd/employee
Public Parks (toilets only)	5 gpd/user
Public Parks with bathhouse	15-25 gpd/user
Car Wash	1200 gpd/bay

Camps:

Construction or Work Camps	60 gpd/person
Summer Camps	60 gpd/person
Campgrounds with Comfort Station (without water & sewer hookups)	100 gpd/campsite
Travel Trailer-R.V. Park (with water & sewer hookups)	120 gpd/space

Assembly & Mercantile:

Retail Stores	120 gpd/1000' of sales area
Stadium, Auditorium	5 gpd/seat
Swimming Pools, Spas, Bathhouses	10 gpd/seat
Churches (not including a kitchen, food service Facility, day care or day camp)	3 gpd/seat
Churches (with a kitchen but not including a Food service facility, day care or day camp)	5 gpd/seat
Country Club	20 gpd/member

Food or Drink Establishment

Café or Restaurant	5 gpd/person
	15 gpd/employee
Tavern or Bar	2 gpd/person
	15 gpd/employee
Fast Food (paper service)	3 gpd/person
	15 gpd/employee
Restaurant serving alcoholic beverages	5 gpd/person
	15 gpd/employee
Restaurant grinding garbage	6 gpd/person
	15 gpd/employee

Type of Establishment

Flow

(Gallons per day (gpd) unless otherwise indicated)

Institutional

Hospitals	300 gpd/bed
Day Car Facilities	15 gpd/person

Residential Care Facilities	60 gpd/person
Rest Homes & Nursing Homes	
with laundry	120 gpd/bed
without laundry	60 gpd/bed
Day Schools	
with cafeteria, gym & showers	15 gpd/student
with cafeteria only	12 gpd/student
with neither cafeteria nor showers	10 gpd/student
Boarding Schools	60 gpd/student

Commercial & Industrial Facilities not listed above (domestic wastewater only)

15 gpd/employee times current rate/gpd **or** total square foot divided by 400 times 15 gpd times current daily rate/gpd.

- D. The applicant may request a variance from the District from the flow contributions if sufficient documentation is provided to justify a lower contribution and if approved by the Board of Trustees.
- E. The capacity fees collected in accordance with this Section shall be placed in an account entitled, "Taney County Regional Sewer District, Capacity Fee Account," and shall be used only for the specific purpose of design and construction of wastewater plants and/or expansion. The balance of the account shall be invested to earn the maximum allowable interest.